

# Certificate of Compliance

Certificate Number 20050406-R2453  
Report Reference R2453, April 7, 1978  
Issue Date 2005 April 6

Page 1 of 1



**Underwriters  
Laboratories Inc.®**

*Issued to:* **Owens Corning**

1 Owens Corning Parkway  
Toledo, OH 43659 U.S.A.

*This is to certify that  
representative samples of*

## **Prepared Roof Covering Materials**

Classic (3-tab), No Cut-Out Style (no tabs), Supreme Metric (3-tab), Classic Metric (3-tab), Oakridge 25 (laminated), Oakridge II (laminated), Supreme (3-tab), Oakridge Shadow, Supreme Shadow, Supreme 30, Prominence, Polar 25, Artic 20, Oakridge 30, Oakridge 40, Glaslock, Weatherguard 30 High Wind 110 and Weatherguard 40 High Wind 110. All products include Standard and AR version - Oakridge Pro 30, Oakridge Pro 40, Woodmoor, Woodcrest - Oakridge Pro 50, Weatherguard H P, Berkshire

*Have been investigated by Underwriters Laboratories Inc.® in  
accordance with the Standard(s) indicated on this Certificate.*


*Standard(s) for Safety:* UL790, Tests for Fire Resistance of Roof Covering Materials.

UL997, Wind Resistance of Prepared Roof Covering Materials; ASTM  
D3462, Specifications for Asphalt Shingles Made With Mineral Granules

*Additional Information:*

When adhesive is appropriately applied to these shingles, they may bear the wind resistance label. In addition, shingle wrappers may be marked "fungus resistant." For installation as Class A Prepared Roof Coverings, on minimum 3/8 in. thick plywood decks with underlayment such as asphalt saturated felt or shingle underlayment Classified by UL as a prepared roof covering.

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory

**Look for the UL Classification Mark on the product**

Issued by

**Martin Rowan**

Underwriters Laboratories Inc.

Reviewed by

**Robert Keogh**

Underwriters Laboratories Inc.